



GUILFORD COUNTY

EMERGENCY SERVICES

MEMORANDUM

TO: Lisa Elmore
Piedmont Triad International Airport

FROM: Kelly Gage *UG*
Guilford County Emergency Services

DATE: March 23, 1993

RE: UST Closure Assessments at PTIA

Lisa, as I indicated over the telephone there are several deficiencies in the closure assessments for the following sites. Listed below each site are the specific deficiencies. Please forward the information requested below to me by April 8, 1993.

Old Blue Bell/Wrangler Hangar Site

- (1) Certificate of Disposal for 10,000 gallon gas tank

Airport Fire Station

- (1) Certificate of Disposal for 550 gallon fuel oil tank
- (2) Description of how samples were preserved
- (3) Description of how tools were decontaminated

Old Gulf Station Site - (5) 3000 gallon gas UST(s), 550 gallon fuel oil, 550 gallon kerosene, 550 gallon waste oil

- (1) Length & Diameter of UST(s)
- (2) Depth of Samples
- (3) Certificate of Disposal for UST(s)
- (4) Chain-of-Custody for Samples
- (5) Description of how samples were collected and preserved
- (6) Description of how tools were decontaminated

Also, please include sampling results from the installation of four (4) monitoring wells (MW) under Permit No. 40-0949-WM-0336 issued on April 1, 1991 to Piedmont Triad International Airport. The consulting firm who filed for the permit was Trigon Engineering.

1002 Meadowood Road • Greensboro, North Carolina 27409
Telephone: (919) 373-7565